

## ADDENDUM NO. ONE (1)

Date: September 23, 2021 Architect's Project No. A20-122GSB

PROJECT: BL102-21 Fire Station #16 & #17 Turnout Gear/Bathroom Renovation Project

Client: Gwinnett County Board of Commissioners

Contract for: General Contracting

*This Addendum forms a part of the Contract Documents and Construction Drawings and modifies the original Bid Documents for the above referenced project.*

### CHANGES TO THE CONTRACT DOCUMENTS

#### A. CHANGES TO THE SPECIFICATIONS

1. **REPLACE** specification section 01 50 00 Temporary Facilities, Controls, and Services with the attached revised version.
2. **REPLACE** specification section 10 51 13 Metal Lockers with the attached revised version.

#### B. CHANGES TO THE DRAWINGS

None

#### C. BIDDER QUESTIONS / CLARIFICATIONS

- Q1. What is the anticipated notice of award date?  
A1. **The project is anticipated to be awarded on 11-16-2021.**
- Q2. Confirming per specification 01 50 00, that dumpsters will be supplied by owner?  
A2. **Dumpsters will be provided and paid for by the General Contractor. Please find the attached revised specification section 01 50 00.**
- Q3. Due to excessive lead times for roofing, would it be possible to substitute 20 PSI ISO in lieu of 25 PSI ISO? Specs attached.  
A3. **Provide 25 psi polyisocyanurate insulation as specified.**
- Q4. Lyon, The basis of design MFG cannot fully meet the specification section 10-51-13 in the project manual. Specifically the highlighted Items attached. Will acceptations be allowed?  
A4. **Please refer to the attached revised specification section 10 51 13 for revised metal locker requirements.**

**D. SUBSTITUTIONS APPROVAL**

**None**

**E. LIST OF ATTACHMENTS**

9/17/2021 Pre-Bid Conference/Site Visit Sign-In Sheet (1 page)

Specification Section 01 50 00 Temporary Facilities, Controls, and Services (6 pages)

Specification Section 10 51 13 Metal Lockers (6 pages)

**PLEASE NOTE: Contractors shall acknowledge receipt of this Addendum on Page 00410-3 of the BIDDING FORM.**

**END OF ADDENDUM NO. ONE (1)**

INSERT DATE

**BL102-21 PRE-BID CONFERENCE**

**Fire Station 16 and 17 Turnout Gear Room and Bathroom Renovation**

Representative Name

Company Name

Phone #

E-Mail Address

**(DEPARTMENT REPRESENTATIVES SIGN-IN AT BOTTOM)**

1. Richard Murray DIVERSIFIED INDUSTRIES 770 241 9485 bradford@geograc.com

2. Ken DeBess AND CONSTRUCTION LLC ~~770 241 9485~~ kddbs@amacoconstruction  
llc.com

3. Cris Gray \_\_\_\_\_

4. \_\_\_\_\_

5. \_\_\_\_\_

6. \_\_\_\_\_

7. \_\_\_\_\_

8. \_\_\_\_\_

9. \_\_\_\_\_

10. \_\_\_\_\_

11. \_\_\_\_\_

12. \_\_\_\_\_

13. \_\_\_\_\_

Department Representative Name

Department

Department Representative Name

Department

Elyshs Wood

PPI

Chris Duncan

DOFS

Michael Williamson

Fire

Cris Gray

Facilities

## SECTION 01 50 00

## TEMPORARY FACILITIES, CONTROLS AND SERVICES

*Revised per Addendum No. 1*

## PART 1 - GENERAL

## 1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General Conditions and other Division 1 and 0 Specifications, apply to this Section.

## 1.02 SUMMARY

- A. Section Includes:
  1. Definitions
  2. Project conditions and scheduling
  3. Temporary construction support facilities
  4. Temporary utilities and services
  5. Special protection requirements
  6. Security – Also refer to Division 0 for detailed requirements
  7. Vehicular access and parking
  8. Termination and removal

## 1.03 DEFINITIONS

- A. Temporary Construction Support Facilities: Construction, structures, fixtures and other built items required to accomplish the Work but which are not incorporated into the finished Work. Included are field offices, storage sheds, temporary roads and paving, temporary enclosures, hoists, dewatering facilities, temporary signs, construction aids and miscellaneous facilities.
- B. Temporary Utilities: Sources of electric power, water, natural gas, etc., obtained from public utilities, other main distribution systems or temporary sources that support the Contractor's activities but are not a part of the permanent construction or are not yet incorporated into the permanent construction.
- C. Temporary Services: Activities and services required during construction that do not directly accomplish the Work. Included are waste disposal services, rodent and pest control, security and miscellaneous services.

## 1.04 PROJECT CONDITIONS AND SCHEDULING

- A. Comply with requirements of regulations, governing authorities and public utilities as to type, quantity, location and use of temporary facilities, utilities and services. Secure and maintain copies of permits, inspection reports or approvals for installation and use of temporary facilities and utilities.
- B. Use of permanent facilities prior to date of Substantial Completion is subject to Owner's conditions. During said approved use, Contractor shall maintain and protect completed work. Specific warranties shall not be reduced or voided by Contractor's use of permanent facilities and systems.
- C. Maintain required temporary facilities until not needed or until Substantial Completion. Exceptions to this requirement may be made by Owner as indicated in above paragraph.

## 1.05 QUALITY ASSURANCE

- A. Regulations: Comply with industry standards and applicable laws and regulations of authorities having jurisdiction including, but not limited to, the following:
  - 1. Building code requirements.
  - 2. Health and safety regulations.
  - 3. Utility company regulations.
  - 4. Police, fire department, and rescue squad rules.
  - 5. Environmental protection regulations.
- B. Standards: Comply with NFPA 241 “Standard for Safeguarding Construction, Alterations, and Demolition Operations,” ANSI A10 Series standards for “Safety Requirements for Construction and Demolition,” and NECA Electrical Design Library “Temporary Electrical Facilities.”
  - 1. Electrical Service: Comply with NEMA, NECA, and UL standards and regulations for temporary electric service. Install service in compliance with NFPA 70 “National Electric Code.”
- C. Inspections: Arrange for authorities having jurisdiction to inspect and test each temporary utility before use. Obtain required certifications and permits.

## PART 2 – PRODUCTS

## 2.01 TEMPORARY CONSTRUCTION FACILITIES

- A. A Construction trailer shall not be allowed for this project. A temporary storage container for tools, and construction materials shall be allow. Coordinate with the Owner for allowable size and location.
- B. Temporary Toilet Units **for construction personal**: Provide self-contained, single-occupant toilet units of the chemical or aerated recirculation. Provide units properly vented and fully enclosed with a glass-fiber-reinforced polyester shell or similar nonabsorbent material.
- C. Lamps and Light Fixtures: Provide general service incandescent lamps of wattage required for adequate illumination. Provide guard cages or tempered-glass enclosures where exposed to breakage. Provide exterior fixtures where exposed to moisture.
- D. Electrical Power Cords: Provide grounded extension cords. Use hard-service cords where exposed to abrasion and traffic. Provide waterproof connectors to connect separate lengths of electric cords if single lengths will not reach areas where construction activities are in progress. Do not exceed safe length-voltage ratio.
- E. Tarpaulins: Provide waterproof fire-resistant UL labeled tarpaulins with flame spread rating of 15 or less.
- F. Fire Extinguishers: Provide hand-carried portable UL-rated Class A fire extinguishers for temporary offices and similar spaces. In other locations, provide hand-carried, portable, UL-rated Class ABC, dry chemical extinguishers or a combination of extinguishers of NFPA recommended classes for the exposures. Comply with NFPA 10 and NFPA 241 for classification, extinguishing agent, and size required by location and class of fire exposure.

- G. Temporary restroom trailers shall be provided and paid for by the General Contractor for both sites. It is the choice of the General Contractor if separate trailers will be provided for each site, or if the construction schedule will be phased so a single trailer can be used, and relocated from one site to the other. However, under no circumstances shall either site be without restroom facilities for any period of time. Delivery schedule, and the location of the temporary trailer, shall be coordinated with the Owner for each site.**
- 1. Restroom trailers shall contain three toilets in private toilet compartments, three sinks counter mounted with continuous countertop, and three showers in private shower compartments. One toilet and compartment, one sink, and one shower and compartment must be fully ADA compliant.**
  - 2. Restroom trailers shall be equipped with the following toilet accessories at a minimum:**
    - a. Toilet paper dispenser, in each toilet compartment.**
    - b. Toilet seat cover dispenser, in each toilet compartment.**
    - c. Coat hook, in each toilet compartment.**
    - d. Sanitary napkin disposal, in each toilet compartment.**
    - e. Soap dispenser with drip tray, at each sink.**
    - f. Paper towel dispenser, one required.**
    - g. Free standing trash can, one required.**
    - h. Soap tray, in each shower compartment.**
    - i. Towel bar, for each shower.**
    - j. Changing bench, one required.**
    - k. 36" ADA compliant grab bar and 42" ADA compliant grab bar, in one toilet compartment.**
    - l. 24" x 24" x 34" ADA compliant shower grab bar, in one shower compartment.**
    - m. ADA compliant shower seat, in one shower compartment.**
    - n. ADA compliant shower head shall be provided in one shower compartment.**
  - 3. Restroom trailers shall be fully heated, air conditioned, and shall have exhaust fans for each toilet compartment.**
  - 4. Restroom trailers shall have water heaters which will provide hot water to both the showers and the sinks.**
  - 5. Restroom trailers shall have internal potable water storage for water supply. Potable water shall be refilled as required by the General Contractor.**
  - 6. Restroom trailers shall have septic water storage tanks. Septic storage tanks shall be emptied as required by the General Contractor.**
  - 7. Restroom trailers shall be configured for the electrical requirements of each site which are 208Y / 120V, 3-Phase / 4-Wire, 200 Amp.**
  - 8. Restroom trailers shall be equipped with both steel access stairs, and an ADA compliant steel access ramp. Both shall be rated for exterior use.**

## PART 3 – EXECUTION

## 3.01 GENERAL INSTALLATION

- A. Use qualified personnel or services for installation of temporary facilities. Provide each facility ready to use when needed to avoid delay. Locate facilities where they will serve the Project adequately and result in minimum interference with performance of the Work. Relocate and modify facilities as needed. Do not remove until facilities are no longer needed or are replaced by authorized use of completed permanent facilities.

## 3.02 CONSTRUCTION SUPPORT FACILITIES

- A. Temporary Storage Facilities: Provide weather tight storage facilities with raised floors and of types and sizes required by storage demands at the Project site. Locations of temporary storage facilities shall be subject to Owner's acceptance. All material storage and staging shall be within the designated limits of the Project site. Contractor is responsible for identifying Project site boundaries and insuring that staging and material storage does not occur outside of the site.
- B. Provide a dedicated area for the storage of tools and equipment within each phased work area. The Contractor will be required to secure all tools at the conclusion of each work day and maintain a log of equipment and tools located on site. Combustibles and hazardous materials shall not be stored inside the building overnight or at any time when construction personnel are not present. The Contractor shall notify the Owner and all such materials shall be approved prior to bringing items into the building.
- C. Temporary Enclosures: As required by the progress and sequencing of the Work, provide temporary enclosures for protection of construction in progress or completed, from exposure to foul weather or other construction operations.
  - 1. Maintain protective barriers, vehicular barriers, temporary fencing, dust control barriers and sound control devices as needed for all phases of construction until final completion of the Project. Barriers and devices shall be coordinated with the staging and sequencing of the Work. Contractor shall be responsible for replacing established protective barriers and devices damaged or removed during construction and shall install any additional protection devices as required to perform the Work under this Contract.
  - 2. Provide temporary signs as required. Install signs where needed to inform personnel, vendors and public seeking entrance to the Project.
  - 3. Security, access and working requirements will be discussed at length during the preconstruction meeting and are outlined in Division 0 of these specifications.
  - 4. The Contractor is responsible for all temporary construction, phasing, scheduling, material deliveries, and other items that affect the sequence of construction or scheduling of the Project.
- D. Sanitary Facilities: Sanitary facilities include temporary toilets, wash facilities, and drinking-water fixtures. Comply with regulations and health codes for the type, number, location, operation, and maintenance of fixtures and facilities. Install where facilities will best serve the Project's needs. Provide applicable paper goods in support of each facility. Provide covered waste containers for used materials.
  - 1. Toilets: Provide and maintain temporarily sited and self-contained toilet units until Substantial Completion on all Work. Do not allow employees to use permanent toilet facilities of the new construction.
  - 2. Wash Facilities: Provide and maintain a safety shower/eye wash facility with potable water at a location convenient for personnel.

3. Drinking Water Facilities: Provide drinking water canisters or fixtures at convenient locations on the Project site. Include cup supply.

### 3.03 TEMPORARY UTILITIES AND SERVICES

- A. General: Temporary electrical and water service shall not be required. The General Contractor shall be allowed to use the existing building electrical and water service.
- B. Telecommunications Services: Maintain cell phones for Project Manager and Superintendent.
- C. Collection and Disposal of Waste: Collect waste from construction areas and elsewhere on Project site **DAILY. Dedicated dumpsters for construction debris shall be provided and paid for by the General Contractor. The General Contractor shall coordinate the allowable size and location on site with the Owner.** Comply with requirements of NFPA 241 for removal of combustible waste material and debris. Enforce requirements strictly. Do not hold waste materials more than 7 days during normal weather or 3 days when the temperature is expected to rise above 80 deg F (27 deg C). Handle hazardous, dangerous, or unsanitary waste materials separately from other waste by containerizing properly. Dispose of material lawfully.

### 3.04 VEHICULAR ACCESS AND PARKING

- A. Haul Routes: The Contractor shall be responsible for insuring that trucks providing delivery and/or hauling services to or from the Project site shall properly cover loads. Contractor shall keep the roads to the Project site and the Project site clear, free of mud, dirt, debris, or other materials that are deposited as a result of Contractor's hauling and delivery services. The Contractor is responsible for coordinating and scheduling hauling activities so that the traffic flow on the access road to the Project site is not disrupted at any time.
- B. Parking Areas: All parking for Contractor's employees, subcontractors' employees, and for vendors, delivery men, and visitors shall be on the Project site and in designated areas of the phasing Construction Documents. Coordinate with the Owner for allowable parking locations.
- C. Traffic Control: The Contractor shall provide all traffic control on streets or drives adjacent to or on the Project site that is needed to facilitate the Contractor's Work and protect the public from activities associated with such work. These controls shall include signs, signals, barricades and flagmen, as necessary. The Contractor shall comply with all local, state, federal rules and regulations concerning the placement and use of traffic control devices

### 3.05 TEMPORARY PROTECTION AND CONTROL

- A. Environmental Protection: Provide protection, operate temporary facilities and conduct construction in ways and by methods that comply with environmental regulations, and minimize the possibility that air, waterways, and subsoil might be contaminated or polluted or that other undesirable effects might result. Maintain protective barriers, tree protection and erosion control devices until Final Completion of the Project. Contractor shall be responsible for replacing established protective barriers, tree protection and erosion control devices damaged or removed during construction and shall install any additional protection devices as required to perform the Work under the Contract.

### 3.06 MAINTENANCE, TERMINATION, AND REMOVAL

- A. Supervision: Enforce strict discipline in use of temporary facilities. Limit availability of temporary facilities to essential and intended uses to minimize waste and abuse.
- B. Maintenance: Maintain facilities in good operating condition until Project completion.



- C. Termination and Removal: Unless the Architect requests that it be maintained longer, remove each temporary facility when the need has ended, when replaced by authorized use of a permanent facility, or no later than Substantial Completion. Complete or, if necessary, restore permanent construction that may have been delayed because of interference from the temporary facility. Repair damaged Work, clean exposed surfaces, and replace construction that cannot be satisfactorily repaired.
1. Materials and facilities that constitute temporary facilities are the Contractor's property. The Owner reserves the right to take possession of Project identification signs.
  2. Remove all trash and debris and restore areas to conditions required by the Contract.

END OF SECTION 01 50 00

## SECTION 10 51 13

## METAL LOCKERS

*Revised per Addendum No. 1*

## PART 1 - GENERAL

## 1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

## 1.02 SUMMARY

- A. This Section includes the following:
  - 1. Metal Lockers

## 1.03 DEFINITIONS

- A. Uncoated Steel Sheet Thicknesses: Indicated as the minimum thicknesses.

## 1.04 SUBMITTALS

- A. General: Submittals shall be in accordance with Specification Section 01 33 00.
- B. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles and installation instructions.
- C. Shop Drawings: Include plans, elevations, sections, details, and attachments to other work.
  - 1. Show base, tops, filler panels, trim and other accessories.
- D. Samples for Verification: Metal color sample for metal lockers, in manufacturer's standard sizes.
- E. Qualification Data: For Contractor's installer, signed by manufacturer certifying that Contractor's installers comply with specified requirements.
- F. Maintenance Data: For adjusting, repairing, and replacing locker doors and latching mechanisms to include in maintenance manuals.
- G. Warranty: Special warranty specified in this section.

## 1.05 QUALITY ASSURANCE

- A. Contractor's Installer Qualifications: An authorized representative of metal locker manufacturer for installation and maintenance of units required for this Project.
- B. Source Limitations: Obtain all similar types of metal lockers and accessories through one source from a single manufacturer.
- C. Product Options: Drawings indicate size, profiles, and dimensional requirements of metal lockers and are based on the specific system indicated.

1. Do not modify intended aesthetic effects, as judged solely by Architect, except with Architect's approval. If modifications are proposed, submit comprehensive explanatory data to Architect for review.

D. Regulatory Requirements:

1. A minimum of one locker required in each room to comply with accessibility requirements, "Accessibility Guidelines for Buildings and Facilities (ADAAG)."
  - a. Provide not less than 1 shelf located no higher than 48 inches (1219 mm) above the floor for forward reach.
  - b. Provide hardware that does not require tight grasping, pinching, or twisting of the wrist, and that operates with a force of not more than 5 lbf.
2. Manufacturer must also be ISO 9001 certified or submit entire detailed manufacturer's control program.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Do not deliver metal lockers until spaces to receive them are clean, dry, and ready for metal locker installation.
- B. Sequence and Scheduling: Sequence installation with other work to minimize possibility of damage and soiling during remainder of construction period.
- C. Deliver master and control to the Owner during Project Closeout.

1.07 PROJECT CONDITIONS

- A. Field Measurements: Verify metal locker locations by field measurements before fabrication and indicate measurements on shop Drawings:

1.08 COORDINATION

- A. Coordinate metal base installation with finish flooring material:
  1. Install locker bases after finishes are complete.
- B. Coordinate sizes and locations of framing, blocking, furring, reinforcements, and other related units of Work specified in other Sections to ensure that metal lockers can be supported and installed as indicated.
- C. Pre-installation Conference: Conduct conference at Project site to comply with requirements of contract. Review methods and procedures related to units including, but not limited to, the following:
  1. Inspect and discuss condition and levelness of flooring and other preparatory work performed under other contracts.
  2. Review structural load limitations.

1.09 WARRANTY

- A. Special Warranty: Manufacturer's standard form in which manufacturer agrees to repair or replace components of metal lockers that fail in materials or workmanship, excluding finish, within specified warranty period. This warranty shall be in addition to and not a limitation of other rights the Owner may have against the Contractor under Contract Documents.

1. Failures include, but are not limited to, the following:
  - a. Structural failures.
  - b. Faulty operation of latches and other door hardware.
2. Damage from deliberate destruction and vandalism is excluded.
3. Warranty Period for All Metal Lockers: 5 years from date of Substantial Completion, lifetime warranty on frame.

#### 1.10 EXTRA MATERIALS

- A. Furnish extra materials described below, before construction begins, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Full-size units of the following metal locker hardware items equal to 5 percent of amount installed for each type and finish installed, but no fewer than 5 units each:
    - a. Identification plates.
    - b. Hooks.

### PART 2 - PRODUCTS

#### 2.01 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  1. Basis-of-Design Product: The design for each metal locker specified is based on the product named. Subject to compliance with requirements, provide either the named product or a comparable product by one of the other manufacturers specified.

#### 2.02 MATERIALS

- A. Cold-Rolled Steel Sheet: ASTM A 1008, Commercial Steel (CS) prime grade, minimum gage requirements as listed below. Commercial-quality cold-rolled carbon sheet steel, stretcher leveled, or roller leveled to stretcher-leveled flatness, free of buckling, scale and surface imperfections.
- B. Hinges: All stainless steel, heavy-duty, continuous piano hinge 1.5 inch open, .062inch thick, 1/8 inch diameter pin, ½ inch knuckle; manufactured to full height of door. Hinge is welded to prevent removal of hinge pin. Hinge welded to door and attached to doorframe with factory installed fasteners that are concealed and tamper resistant when door is closed.
- C. Fasteners: Zinc- or nickel-plated steel, slotless-type exposed bolt heads, and self-locking nuts or lock washers for nuts on moving parts. Steel rivets used to secure internal mating sheets for operating mechanisms. There are no protruding fasteners on any exterior part of the cabinet.
- D. Finish: The surface of the steel shall be cleaned thoroughly in a multi-stage phosphatizing and metal preparation process to inhibit corrosion and increase the durability of the applied finish. Minimum 1.5 mil powder paint finish coat shall be electro-statically applied and baked on at over 400 degrees. All lockers shall be painted the same color inside and out.
- E. Equipment: All locking and door operating system components shall be zinc plated, nickel plated, stainless steel or painted steel to inhibit corrosion.

- F. Number Plates: Manufacturer's standard etched, embossed, or engraved, plastic number plates with numerals at least ½ inch high. Number all lockers in sequence using a three number system. Attach plates to each locker door, near top, centered, with at least two aluminum rivets.
- G. Anchors: Select material, type, size, and finish required for secure anchorage to each substrate.
  - 1. Provide nonferrous-metal or hot-dip galvanized anchors and inserts for corrosion resistance.

### 2.03 METAL LOCKERS

- A. Acceptable Manufacturers:
  - 1. Lyon:
    - a. Basis of Design:
      - 1) Lyon – Heavy-Duty Steel Lockers
    - b. Other manufacturers desiring approval comply with Specification Section 01 63 00 Product Substitution Procedures.
- B. **Refer to Locker Schedule at the end of PART 3 for additional information.**

## PART 3 - EXECUTION

### 3.01 EXAMINATION

- A. Examine walls, floors, and support bases, with Contractor's installer present, for compliance with requirements for installation tolerances and other conditions affecting performance of work.
  - 1. For the record, prepare written report, endorsed by Contractor's installer, listing conditions detrimental to performance of work.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.02 INSTALLATION

- A. General: Install level, plumb, and true; shim as required, using concealed shims.
  - 1. Use factory trained and certified Installers.
  - 2. Follow all manufacturer supplied installation specifications without deviation.
  - 3. Perform a post installation walk-thru with the Owner for verification of specification adherence and overall performance of the locker system.
- B. Anchor lockers/bases to the floor and wall as recommended by the manufacturer to suit the adjacent materials and finishes.
- C. Equipment and Accessories: Fit exposed connections of trim, fillers, and closures accurately together to form tight, hairline joints, with concealed fasteners and splice plates.
  - 1. Attach hooks with at least two fasteners.
  - 2. Identification Plates: Identify metal lockers with identification plates as specified.
    - a. Attach plates to each locker door, near top, centered, with at least two aluminum rivets.
  - 3. Attach filler panels with concealed fasteners. Locate filler panels as required for a complete installation.
  - 4. Attach boxed end panels with concealed fasteners to conceal exposed ends of non-recessed metal lockers.

3.03 ADJUSTING, CLEANING, AND PROTECTION

- D. Clean, lubricate, and adjust hardware. Adjust doors and latches to operate easily without binding. Verify that integral locking devices operate properly.
- E. Protect metal lockers from damage, abuse, dust, dirt, stain, or paint. Do not permit metal locker use during construction.
- F. Touch up marred finishes, or replace metal lockers that cannot be restored to factory-finished appearance. Use only materials and procedures recommended or furnished by metal locker manufacturer.

**Refer to Locker Schedule of Equipment on next page.**

**LOCKER SCHEDULE OF EQUIPMENT**

<b>Item Number:</b>	<b>Refer to Drawings</b>
<b>Manufacturer:</b>	<b>Lyon</b>
Item/Description:	<p>Lyon Heavy-Duty Steel Lockers with welded frame consisting of minimum 16 gauge body, with 18 gauge steel back. 14 gauge single piece doors. Reinforcements, and other components shall be 16 gauge minimum. Provide mounting holes for attaching tops, end panels, fillers, backs, sides, and adjacent lockers.</p> <p>Provide air vents in top and bottom of locker door.</p> <p>Bottom and top open for access to fasten unit to floor and wall during installation.</p> <p>Hinges shall be not less than 2" high, .050" steel, 5 knuckle, full loop design forming double thickness on each leaf. Hinges to be set in slot in door and frame and projection welded to frame and securely attached to door. Hinge pin to be spun over at ends to resist removal. Each locker shall have two hinges all on right hand side of door.</p> <p>Door shall include rubber or neoprene bumper for noise reduction.</p> <p>Each locker shall be provided with stainless steel recessed handles with finger lift.</p> <p>Each locker shall have one double prong hook, and three single prong wall hooks. All hooks to be zinc-plated or subjected to a comparable rust retardant treatment, and attached with two bolts. Each locker shall also be provided with a 5/8" diameter coat rods, which is not standard for this locker size. The coat rod must be ordered as an additional accessory.</p> <p>Each locker shall be provided with a number plate pop riveted in pre-drilled holes on door, numbering system shall be approved by the owner prior to installation.</p> <p>Finished end panels shall be provided without exposed fasteners.</p> <p>Finish shall be minimum 3 mil. thick factory-applied baked-on textured power finish.</p> <p>Lockers shall be furnished with 6" legs.</p> <p>Provide flat top.</p> <p>Lockers shall arrive on-site fully assembled.</p>
Dimensions:	18" wide, 24" deep, 36" high, Double Tier
Finish:	Red Baron (To Be Confirmed During the Submittal Process) <b>Lockers shall be the same color on all surfaces both inside and out. This does not come standard, and must be requested when ordering. This is additional cost, and must be included in the base bid.</b>
Warranty:	Lifetime warranty on the frame; 5 year limited warranty on moving parts.

END OF SECTION 10 51 13